

## TJ223PE5A

## Diesel Generator Sets / 50 Hz

Power Output Ratings		50 Hz / 400 V
Standby Power (ESP)	kVA	223
	kW	178
Prime Power (PRP)	kVA	203
	kW	162

Engine				
Manufacturer			PERKINS	
Origin			CHINA	
Model			1106A -70TAG4	
No of Cylinder / Configuration			6 - INLINE	
Displacement		lt	7,01	
Bore / Stroke		mm	105 / 135	
Compression Ratio			16:1	
Aspiration			Turbocharged and Air to-Air Charged Cooled	
Governor Type			ELECTRONIC/ECM	
Cooling System			WATER	
Coolant Capacity		lt	21	
Lubrication Oil Capacity		lt	16,5	
Electrical System		VDC	12	
Speed / Frequency			1500 rpm / 50 Hz	
Engine Gross Power		kWm	196	
		110 %	49,4	
Fuel Consumption I	t/h	100 %	45,8	
i dei Gonsumption		75 %	34,3	
		50 %	22,9	
Exhaust Outlet Temperature		°C	580	
Exhaust Gas Flow		m³/min	36,8	
Combustion Air Flow		m³/min	13,2	
Cooling Air Flow		m³/min	282	

Alternator					
Manufacturer		MARELLI			
Origin					
odel		MJB250LA4			
o of Phase		3			
Power Factor	actor				
No of Bearing	of Bearing				
No of Poles		4			
No of Leads	12				
Voltage Regulation ( Steady State)	± %0,5				
Insulation Class		Н			
Degree of Protection		IP 23			
Excitation System		AVR (Automatic Voltage Regulator), Brushless			
Connection Type		STAR			
Total Harmonic Content (No Load)		< %2			
Frequency	Hz	50			
Voltage Output	VAC	230 / 400			
Rated Power (Standby)	kVA	240			
Efficiency	%	93,2			
•		- 7			

	W x L x H (mm)	Weight (kg)	Fuel Tank (It)	Noise dB(A)
Canopied	1037 x 3265 x 1700	TBA	168	TBA
Open Skid	750 x 2520 x 1520	TBA	144	TBA






## Standby Power

Standby power is defined as the maximum power available during a variable electrical power sequence, under the stated operating conditions, for which a generating set is capable of delivering in the event of a utility power outage or under test conditions for up to 500 hours of operation per year under average of 70% load. Overloading is not permissible.

## Prime Power

Prime power is defined as being the maximum power which a generating set is capable of delivering continuously whilst supplying a variable electrical load. Average load should be 70%. The generator can be overloaded 10% for 1 hour per 12 hours.



- Technical information and values are according to ISO8528, ISO3046,NEMA MG-1.22, IEC 60034-1, BS 4999-5000, VDE 0530 standards. Producing with ISO9001, ISO14001, OHSAS18001, TSE, CE standards.

TBA: To Be Ask

- All information given in this leaflet is intended for general purposes only. Due to a policy continuous improvement Teksan reserves the right to amend details and specifications without notice and all information given is subject to the Teksan's current condition of sales.

**TBD:** To Be Determined **NA:** Not Avaliable www.teksangenerator.com

TTD223PE5A0612-EN N/A: Not Applicable

