

TJ275PE5S

Diesel Generator Sets / 50 Hz

Power Output Ratings		50 Hz / 400 V	
Standby Power (ESP)	kVA	275	
	kW	220	
Prime Power (PRP)	kVA	250	
	kW	200	

Engine				
Manufacturer			PERKINS	
Origin			U.S.A.	
Model			1306C-E87TAG6	
No of Cylinder / Configuration			6 - INLINE	
Displacement		lt	8,7	
Bore / Stroke		mm	116,6 / 135,9	
Compression Ratio			16,9:1	
Aspiration			Turbocharged and Air-to-Air Charged Cooled	
Governor Type			ELECTRONIC/ECM	
Cooling System			WATER	
Coolant Capacity		lt	37,2	
Lubrication Oil Capacity		lt	28,3	
Electrical System		VDC	24	
Speed / Frequency			1500 rpm / 50 Hz	
Engine Gross Power		kWm	246	
	lt/h _	110 %	49,7	
Fuel Consumption		100 %	45	
ruei Consumption		75 %	36	
		50 %	24	
Exhaust Outlet Temperature		°C	528	
Exhaust Gas Flow		m³/min	44,5	
Combustion Air Flow		m³/min	16,4	
Cooling Air Flow		m³/min	375	

Alternator						
Manufacturer		STAMFORD				
Origin						
odel		HCI444C				
No of Phase	of Phase					
Power Factor	r Factor					
No of Bearing	of Bearing					
lo of Poles		4				
No of Leads		12				
Voltage Regulation (Steady State)	± %1					
Insulation Class	Н					
Degree of Protection		IP 23				
Excitation System		AVR (Automatic Voltage Regulator), Brushless				
Connection Type		STAR				
Total Harmonic Content (No Load)		< %2				
Frequency	Hz	50				
Voltage Output	VAC	230 / 400				
Rated Power (Standby)	kVA	275				
Efficiency	%	92,2				

	W x L x H (mm)	Weight (kg)	Fuel Tank (It)	Noise dB(A)
Canopied	TBA x TBA x TBA	TBA	TBA	TBA
Open Skid	TBA x TBA x TBA	TBA	TBA	TBA






Standby Power

Standby power is defined as the maximum power available during a variable electrical power sequence, under the stated operating conditions, for which a generating set is capable of delivering in the event of a utility power outage or under test conditions for up to 500 hours of operation per year under average of 70% load. Overloading is not permissible.

Prime Power

Prime power is defined as being the maximum power which a generating set is capable of delivering continuously whilst supplying a variable electrical load. Average load should be 70%. The generator can be overloaded 10% for 1 hour per 12 hours.



- Technical information and values are according to ISO8528, ISO3046,NEMA MG-1.22, IEC 60034-1, BS 4999-5000, VDE 0530 standards. Producing with ISO9001, ISO14001, OHSAS18001, TSE, CE standards.

TBA: To Be Ask

- All information given in this leaflet is intended for general purposes only. Due to a policy continuous improvement Teksan reserves the right to amend details and specifications without notice and all information given is subject to the Teksan's current condition of sales.

TBD: To Be Determined **NA:** Not Avaliable www.teksangenerator.com

TTD275PE5S0612-EN N/A: Not Applicable

