

## **TJ302PE5S**

## Diesel Generator Sets / 50 Hz

Power Output Ratings		50 Hz / 400 V
Standby Power (ESP)	kVA	302
	kW	241
Prime Power (PRP)	kVA	276
	kW	220

Engine			
Manufacturer		PERKINS	
Origin		U.S.A.	
Model		1606A -E93TAG4	
No of Cylinder / Configuration		6 - INLINE	
Displacement	lt	9,3	
Bore / Stroke	mm	116,6 / 146	
Compression Ratio		17,2:1	
Aspiration		Turbocharged and Air-to-Air Charged Cooled	
Governor Type		ELECTRONIC/ECM	
Cooling System		WATER	
Coolant Capacity	lt	30,9	
Lubrication Oil Capacity	lt	33	
Electrical System	VDC	24	
Speed / Frequency		1500 rpm / 50 Hz	
Engine Gross Power	kWm	271	
	110 %	61	
Fuel Consumption It/h	100 %	56	
i dei consumption	75 %	44	
	50 %	32	
Exhaust Outlet Temperature	°C	400	
Exhaust Gas Flow	m³/min	22,8	
Combustion Air Flow	m³/min	21,6	
Cooling Air Flow	m³/min	609	

Alternator						
Manufacturer		STAMFORD				
Origin						
lodel		HCI444D				
No of Phase		3				
Power Factor		0,8				
No of Bearing		SINGLE				
No of Poles		4				
No of Leads		12				
Voltage Regulation ( Steady State)		± %1				
Insulation Class		Н				
Degree of Protection		IP 23				
Excitation System		AVR (Automatic Voltage Regulator), Brushless				
Connection Type		STAR				
Total Harmonic Content (No Load)		< %2				
Frequency	Hz	50				
Voltage Output	VAC	230 / 400				
Rated Power (Standby)	kVA	330				
Efficiency	%	92,5				

	W x L x H (mm)	Weight (kg)	Fuel Tank (It)	Noise dB(A)
Canopied	TBA x TBA x TBA	TBA	TBA	TBA
Open Skid	TBA x TBA x TBA	TBA	TBA	TBA






## Standby Power

Standby power is defined as the maximum power available during a variable electrical power sequence, under the stated operating conditions, for which a generating set is capable of delivering in the event of a utility power outage or under test conditions for up to 500 hours of operation per year under average of 70% load. Overloading is not permissible.

## Prime Power

Prime power is defined as being the maximum power which a generating set is capable of delivering continuously whilst supplying a variable electrical load. Average load should be 70%. The generator can be overloaded 10% for 1 hour per 12 hours.



- Technical information and values are according to ISO8528, ISO3046,NEMA MG-1.22, IEC 60034-1, BS 4999-5000, VDE 0530 standards. Producing with ISO9001, ISO14001, OHSAS18001, TSE, CE standards.
- All information given in this leaflet is intended for general purposes only. Due to a policy continuous improvement Teksan reserves the right to amend details and specifications without notice and all information given is subject to the Teksan's current condition of sales.

TBA: To Be Ask **TBD:** To Be Determined **NA:** Not Avaliable www.teksangenerator.com

N/A: Not Applicable

**₹**(€ TTD302PE5S0612-EN

