

TJ665PE5S

Diesel Generator Sets / 50 Hz

Power Output Ratings		50 Hz / 400 V
Standby Power (ESP)	kVA	665
	kW	532
Prime Power (PRP)	kVA	610
	kW	488

Engine				
Manufacturer			PERKINS	
Origin			U.S.A.	
Model			2806A -E18TAG1A	
No of Cylinder / Configuration			6 - INLINE	
Displacement		It	18,13	
Bore / Stroke		mm	145 / 183	
Compression Ratio			14,5:1	
Aspiration			Turbocharged and Air to-Air Charged Coole	
Governor Type			ELECTRONIC/ECM	
Cooling System	-		WATER	
Coolant Capacity		lt	61	
Lubrication Oil Capacity		It	62	
Electrical System		VDC	24	
Speed / Frequency			1500 rpm / 50 Hz	
Engine Gross Power		kWm	592,7	
	lt/h	110 %	134	
Fuel Consumption		100 %	123	
Fuel Consumption		75 %	90	
		50 %	61	
Exhaust Outlet Temperature		°C	571	
Exhaust Gas Flow		m³/min	104	
Combustion Air Flow		m³/min	36	
Cooling Air Flow		m³/min	702	

Alternator					
Manufacturer		STAMFORD			
Origin		INDIA			
Model		HCI544E			
No of Phase		3			
Power Factor		0,8			
No of Bearing		SINGLE			
No of Poles		4			
No of Leads		12			
Voltage Regulation (Steady State)		± %1			
Insulation Class		н			
Degree of Protection		IP 23			
Excitation System		AVR (Automatic Voltage Regulator), Brushless			
Connection Type		STAR			
Total Harmonic Content (No Load)		< %2			
Frequency	Hz	50			
Voltage Output	VAC	230 / 400			
Rated Power (Standby)	kVA	665			
Efficiency	%	94,5			

	W x L x H (mm)	Weight (kg)	Fuel Tank (It)	Noise dB(A)
Canopied	TBA x TBA x TBA	TBA	TBA	TBA
Open Skid	TBA x TBA x TBA	TBA	TBA	TBA






Standby Power

Standby power is defined as the maximum power available during a variable electrical power sequence, under the stated operating conditions, for which a generating set is capable of delivering in the event of a utility power outage or under test conditions for up to 500 hours of operation per year under average of 70% load. Overloading is not permissible.

Prime Power

Prime power is defined as being the maximum power which a generating set is capable of delivering continuously whilst supplying a variable electrical load. Average load should be 70%. The generator can be overloaded 10% for 1 hour per 12 hours.



- Technical information and values are according to ISO8528, ISO3046,NEMA MG-1.22, IEC 60034-1, BS 4999-5000, VDE 0530 standards. Producing with ISO9001, ISO14001, OHSAS18001, TSE, CE standards.

TBA: To Be Ask

- All information given in this leaflet is intended for general purposes only. Due to a policy continuous improvement Teksan reserves the right to amend details and specifications without notice and all information given is subject to the Teksan's current condition of sales.

TBD: To Be Determined **NA:** Not Avaliable www.teksangenerator.com

TTD665PE5S0612-EN N/A: Not Applicable

